

CEGB INSTRUMENT & CONTROL EQUIPMENT FULL APPROVALS

Model	Approval No.	Measured Value	Movement	Scale
FIESTA 016* 016*	5138, A2-Issue 1 5119, A7-Issue 2	Ammeter, Voltmeter T.P.I	MI, MC Power separately	100°, 240° 240°
UNIFIX 056 056	5138, A2-Issue 1 5119, A7-Issue 2	Ammeter, Voltmeter T.P.I	MI, MC Power separately	100°, 240° 240°
057 058 057, 058 057, 058	5138, A3-Issue 1 5138, A3-Issue 1 5119, A7-Issue 2 5103, A10-Issue 3	Ammeter, Voltmeter Ammeter, Voltmeter T.P.I Wattmeter, Varmeter	MI, MC MI, MC Self-contained Single & 3 Phase	100°, 240° 240° 240° 240°
057, 058	5104, A14-Issue 2	Synchroscope	Rotating vane	360°
QUADRATIC 242	5102, A52-Issue 1	Milliammeter	MC-	90°
242 243,244, 246 244,246 244,246 244,246	5138, A4-Issue 1 5138, A4-Issue 1 5119, A7-Issue 2 5103, A14-Issue 1 5104, A14-Issue 1	Ammeter, Voltmeter Ammeter, Voltmeter T.P.I Wattmeter, Varmeter Synchroscope	MI, MC MI, MC Self-contained Self-contained Rotating Vane	240° 90°, 240° 240° 240° 360°
Specify type No 7 th digit 'C' Instruments comply with CEGB-EM5(1978) and BS EN 60051 (BS89) *71mm barrel, Polycarbonate window				

DRG No. 28376-01 revision 8

The Information contained in these installation instructions is for use only by installers trained to make electrical power installations and is intended to describe the correct method of installation for this product. However, Tyco Electronics has no control over the field conditions, which influence product installation. It is the user's responsibility to determine the suitability of the installation method in the user's field conditions. Tyco Electronics' only obligations are those in Tyco Electronics' standard Conditions of Sale for this product and in no case will Tyco Electronics be liable for any other incidental, indirect or consequential damages arising from the use or misuse of the products. Crompton is a trade mark.



Tyco Electronics UK Limited

Crompton Instruments

Freebournes Road, Witham, Essex, CM8 3AH, UK

Phone: +44 1376 509 509 Fax: +44 1376 509 511

<http://energy.tycoelectronics.com>